

# CERTIFICATE of Conformity



**Certificate No.:** MK 69243433 0001

**Test Report No.:** 28216831 001

**Certificate Holder:** FRONIUS International GmbH  
Günter Fronius Straße 1  
4600 Thalheim bei Wels  
Austria

**Manufacturer:** FRONIUS International GmbH  
Günter Fronius Straße 1  
4600 Thalheim bei Wels  
Austria

**Product:** Photovoltaic (PV) Grid-tied inverter

**Identification:** Type designation: Fronius Galvo Family  
a, Fronius Galvo 3.1-1  
b, Fronius Galvo 3.0-1  
c, Fronius Galvo 2.5-1  
d, Fronius Galvo 2.0-1  
e, Fronius Galvo 1.5-1  
Max. DC input voltage(V): a, b, c:550; d, e:420  
Operating DC input voltage(V): a, b, c:165-440;  
d, e: 120-335  
Max. DC input current(A): a)20,2; b)19,5; c)16,2;  
d)17,8; e)13,3  
Nominal AC output power(W): a)3100; b)3000; c)2500;  
d)2000; e)1500  
Max AC output current (A): a) 13,5; b) 13; c)10,9;  
d) 8,7; e) 6,5  
Nominal voltage: 230 V; Phase:1  
Trademark: Fronius

**Tested according to:** AS 4777.2:2005  
AS 4777.3:2005  
AS/NZS 3100:2009 inc. amendment 1

This certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the requirements stated above. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

**Date of Issue:**

Budapest, 2012.12.17



TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Váci út 48/A-B — www.tuv.hu

IT\_07-D-Pe\_4\_0