



Wels, November 6th 2018

CONFORMITY WITH PROTECTIVE CLASS I ACCORDING TO IEC 62109-1

Fronius International GmbH

hereby confirms that the Fronius inverters

- / **Fronius Primo 3.0-1 – 8.2-1**
- / **Fronius Galvo 1.5-1 – 3.1-1**
- / **Fronius Symo 3.0-3-S – 4.5-3-S**
- / **Fronius Symo 3.0-3-M – 20.0-3-M**
- / **Fronius Symo Hybrid 3.0-3-S – 5.0-3-S**
- / **Fronius Eco 25.0 – 27.0**

Fulfil the requirements for protective class I according to IEC 62109-1 "Safety of power converters for use in photovoltaic power systems – Part 1: General requirements".

This means that the protection against electric shock is realized by means of basic isolation and protective earthing of accessible conductive parts, so that accessible conductive parts cannot become live in the event of a failure of the basic insulation.

Fronius International GmbH

Business Unit Solar Energy
Froniusplatz 1
A-4600 Wels

A handwritten signature in blue ink, appearing to read "Martin Heidl".

DI Dr. Martin Heidl
Head of Systems Technology